

RADHASOAMI DAYAL KI DAYA RADHASOAMI SAHAI

WATER QUALITY MONITORING REPORT
Most Probable Number (MPN) of Bacteria in Dayalbagh Wells

Date of Reporting : 12-Apr-2021

Date of Sampling : 09-Apr-2021

Permissible limit for MPN is <10 and for pH is 6.5 to 8.5

S.No.	Name of Well	MPN Of Bacteria in Sample (Per ml)		Is MPN Below Permissible Limit of 10	KMnO ₄ Colour		pH	Remarks and Instructions
		Current Value	Previous Value		Current	Previous		
1	Gangavas	7.2	7.4	Yes	Light Pink	Light Pink	6.8	
2	Dayal Nagar	6.1	6.1	Yes	"	"	6.9	
3	Prem Nagar	6.1	6.1	Yes	"	"	6.9	
4	Dunn Tubewell	3.0	6.2	Yes	"	"	7.3	
5	Punjabi Farm	7.4	7.4	Yes	"	"	7.1	
6	Dairy West	6.1	3.6	Yes	"	"	6.9	
7	Pavan Kuan	7.2	3.0	Yes	"	"	7.1	
8	DEI Dairy	3.0	7.2	Yes	"	"	7.4	
9	Ganga Jal	7.4	7.4	Yes	"	"	7.5	
10	Gaushala	7.4	7.4	Yes	"	"	7.5	

Note : A continuous study conducted as part of Dayalbagh Sigma Six Qualities, Values and Attributes Model