

RADHASOAMI DAYAL KI DAYA RADHASOAMI SAHAI

WATER QUALITY MONITORING REPORT
Most Probable Number (MPN) of Bacteria in Dayalbagh Wells

Date of Reporting : 10-July-2021

Date of Sampling : 07-July-2021

Permissible limit for MPN is <10 and for pH is 6.5 to 8.5

S.No.	Name of Well	MPN Of Bacteria in Sample (Per ml)		Is MPN Below Permissible Limit of 10	KMnO ₄ Colour		pH
		Current Value	Previous Value		Current	Previous	
1	Gangavas	3.6	7.4	Yes	Light Pink	Light Pink	6.0
2	Dayal Nagar	7.4	6.1	Yes	"	"	6.9
3	Prem Nagar	3.6	7.2	Yes	"	"	6.8
4	Dunn Tubewell	7.2	6.1	Yes	"	"	7.1
5	Punjabi Farm	6.1	7.4	Yes	"	"	6.9
6	Dairy West	6.2	6.2	Yes	"	"	7.0
7	Pavan Kuan	7.4	7.2	Yes	"	"	7.1
8	DEI Dairy	7.2	3.6	Yes	"	"	7.4
9	Ganga Jal	7.4	7.4	Yes	"	"	7.3
10	Gaushala	6.2	7.2	Yes	"	"	7.4

Note : A continuous study conducted as part of Dayalbagh Sigma Six Qualities, Values and Attributes Model