

**RADHASOAMI DAYAL KI DAYA RADHASOAMI SAHAI**

**WATER QUALITY MONITORING REPORT**  
**Most Probable Number (MPN) of Bacteria in Dayalbagh Wells**

Date of Reporting : 05-June-2022


Date of Sampling : 03-June-2022

**WHO Prescribed Permissible limit for MPN is <10 and for pH is 6.5 to 8.5**

| S.No. | Name of Well  | MPN Of Bacteria in Sample (Per ml) |                | Is MPN Below Permissible Limit of 10? | KMnO <sub>4</sub> Colour |            | pH            |                |
|-------|---------------|------------------------------------|----------------|---------------------------------------|--------------------------|------------|---------------|----------------|
|       |               | Current Value                      | Previous Value |                                       | Current                  | Previous   | Current Value | Previous Value |
| 1     | Gangavas      | 3.6                                | 3.6            | Yes                                   | Light Pink               | Light Pink | 7.4           | 7.4            |
| 2     | Dayal Nagar   | 3.0                                | 3.0            | "                                     | "                        | "          | 7.3           | 7.2            |
| 3     | Prem Nagar    | 3.6                                | 3.6            | "                                     | "                        | "          | 7.4           | 7.4            |
| 4     | Dunn Tubewell | 3.0                                | 3.0            | "                                     | "                        | "          | 7.2           | 7.4            |
| 5     | Punjabi Farm  | 3.6                                | 3.6            | "                                     | "                        | "          | 7.4           | 7.3            |
| 6     | Dairy West    | 3.0                                | 3.0            | "                                     | "                        | "          | 7.4           | 7.4            |
| 7     | Pavan Kuan    | 3.6                                | 3.6            | "                                     | "                        | "          | 7.3           | 7.2            |
| 8     | DEI Dairy     | 3.6                                | 3.6            | "                                     | "                        | "          | 7.4           | 7.4            |
| 9     | Ganga Jal     | 3.6                                | 3.6            | "                                     | "                        | "          | 7.4           | 7.3            |
| 10*   | Gaushala      | 3.6                                | 6.1            | "                                     | "                        | "          | 7.3           | 7.4            |

**Remarks of Water Quality Research Group:** No specific remedial action is recommended as MPN and pH values are within Permissible Limits. \* W.r.t Gaushala, the quantity of KMnO<sub>4</sub> had been increased from May 29, 2022 to reduce MPN. There has been observable improvement by HIS Grace.

Perused By Way of Information Only,  
Subject To Legalise/Legalese/"Laws of the Land".

  
Sunday, 05-06-2022, 01:41 PM  
Received, Sunday, 05-06-2022, 10:22 AM

**Remarks of Revered Chairman-ACE:**

- 1) The study aims at continuous monitoring of potable well water to detect the presence of coliforms using the "multiple fermentation tube" or "most probable number" technique.
- 2) In this method measured portions of a water sample are placed in test-tubes containing a culture medium. The tubes are then incubated for a standard time at a standard temperature. It is customary to report the results of the multiple fermentation tube test for coliforms as a most probable number (MPN) index. This is an index of the number of coliform bacteria that, more probably than any other number, would give the results shown by the test.
- 3) As a standard remedy, Potassium Permanganate is added in the ratio of 0.1 gm per litre to well water if MPN exceeds permissible limit. If the pH is less than permissible limits i.e., it is acidic, Hydrated Lime Powder i.e.,  $\text{Ca(OH)}_2$  is added in the ratio of 0.037 gms per litre of water. The two remedial processes mentioned above are periodically repeated till the desired water quality is achieved.