

RADHASOAMI DAYAL KI DAYA RADHASOAMI SAHAI

WATER QUALITY MONITORING REPORT
Most Probable Number (MPN) of Bacteria in Dayalbagh Wells

Date of Reporting : 27-June-2021

Date of Sampling : 24-June-2021

Permissible limit for MPN is <10 and for pH is 6.5 to 8.5

S.No.	Name of Well	MPN Of Bacteria in Sample (Per ml)		Is MPN Below Permissible Limit of 10	KMnO ₄ Colour		pH
		Current Value	Previous Value		Current	Previous	
1	Gangavas	7.2	7.2	Yes	Light Pink	Light Pink	6.8
2	Dayal Nagar	3.6	7.4	Yes	"	"	6.9
3	Prem Nagar	6.1	6.2	Yes	"	"	7.0
4	Dunn Tubewell	7.4	7.4	Yes	"	"	7.1
5	Punjabi Farm	7.4	7.0	Yes	"	"	7.3
6	Dairy West	7.2	7.2	Yes	"	"	7.2
7	Pavan Kuan	6.1	6.1	Yes	"	"	6.9
8	DEI Dairy	7.4	6.2	Yes	"	"	7.1
9	Ganga Jal	7.2	7.4	Yes	"	"	7.3
10	Gaushala	6.2	7.4	Yes	"	"	7.3

Note : A continuous study conducted as part of Dayalbagh Sigma Six Qualities, Values and Attributes Model