

**RADHASOAMI DAYAL KI DAYA RADHASOAMI SAHAI**

**WATER QUALITY MONITORING REPORT**

**Most Probable Number (MPN) of Bacteria in Dayalbagh Wells**

Date of Reporting : 18-Sept-2021

Date of Sampling : 15-Sept-2021

**Permissible limit for MPN is <10 and for pH is 6.5 to 8.5**

S.No.	Name of Well	MPN Of Bacteria in Sample (Per ml)		Is MPN Below Permissible Limit of 10?	KMnO <sub>4</sub> Colour		pH
		Current Value	Previous Value		Current	Previous	
1	Gangavas	7.4	7.2	Yes	Light Pink	Light Pink	6.9
2	Dayal Nagar	7.4	7.4	"	"	"	6.9
3	Prem Nagar	7.2	3.0	"	"	"	7.0
4	Dunn Tubewell	7.4	6.1	"	"	"	7.0
5	Punjabi Farm	3.6	7.2	"	"	"	6.9
6	Dairy West	3.6	3.0	"	"	"	7.0
7	Pavan Kuan	3.0	3.6	"	"	"	7.0
8	DEI Dairy	7.4	7.2	"	"	"	7.1
9	Ganga Jal	7.2	7.2	"	"	"	7.1
10	Gaushala	7.2	6.1	"	"	"	7.0

- HoD - Water Supply Dept., Dayalbagh, has got well treatment done with KMnO<sub>4</sub> under strict supervision on 16.09.2021, as pump operators had not done effective treatment on his previous instructions last week.

Remarks of GH today:



Received -Saturday, 18 September 2021, 3:02 PM

Saturday, 18 September 2021, 11:01 AM

chnique.  
a standard  
number of  
imits i.e., it  
eriodically